

Compliance Document for New Zealand Building Code Clause G10 Piped Services

Prepared by the Department of Building and Housing

This Compliance Document is prepared by the Department of Building and Housing. The Department of Building and Housing is a Government Department established under the State Sector Act 1988.

Enquiries about the content of this document should be directed to:



Department of
Building and Housing

Te Tari Kaupapa Whare

Department of Building and Housing
PO Box 10-729, Wellington.
Telephone 0800 242 243
Fax 04 494 0290
Email: info@dbh.govt.nz



Sales enquiries should be directed to:
Customer Services,
Victoria University Book Centre
PO Box 12-337, Wellington, New Zealand
Telephone 0800 370 370, (04) 463 5511
Fax (04) 463 5510
Email: dbh@vicbooks.co.nz
www.vicbooks.co.nz
ISBN 0-477-01606-5

© Department of Building and Housing 2006

This Compliance Document is protected by Crown copyright, unless indicated otherwise. The Department of Building and Housing administers the copyright in this document. You may use and reproduce this document for your personal use or for the purposes of your business provided you reproduce the document accurately and not in an inappropriate or misleading context. You may not distribute this document to others or reproduce it for sale or profit.

The Department of Building and Housing owns or has licences to use all images and trademarks in this document. You must not use or reproduce images and trademarks featured in this document for any purpose (except as part of an accurate reproduction of this document) unless you first obtain the written permission of the Department of Building and Housing.

Status of Compliance Documents

Compliance Documents are prepared by the Department of Building and Housing in accordance with section 22 of the Building Act 2004. A Compliance Document is for use in establishing compliance with the New Zealand Building Code.

A person who complies with a Compliance Document will be treated as having complied with the provisions of the Building Code to which the Compliance Document relates. However, a Compliance Document is only one method of complying with the Building Code. There may be alternative ways to comply.

Users should make themselves familiar with the preface to the New Zealand Building Code Handbook, which describes the status of Compliance Documents and explains alternative methods of achieving compliance.

Defined words (italicised in the text) and classified uses are explained in Clauses A1 of the Building Code and in the Definitions at the start of this Compliance Document.

G10: Document History			
	Date	Alterations	
First published	July 1992		
Amendment 1	September 1993	pp. vi–vii, References p. 3, 1.0.1 p. 4, Table 1	p. 7, 2.0.1 b) p. 10, Index
Amendment 2	1 December 1995	pp. i and ii, Document History	p. vi–viii, References
Reprinted incorporating Amendments 1 & 2	April 1996		
Amendment 3	28 February 1998	p. ii, Document History p. vii, References	p. 8, 5.0.1
Amendment 4	23 June 2007	p. 2, Document History, Status p. 8, References p. 11, Definitions	p. 13, VM1 1.0.1 p. 20, AS1 5.0, 5.0.1 p. 21, Index
Note: Page numbers relate to the document at the time of Amendment and may not match page numbers in current document.			

Document Status

The most recent version of this document, as detailed in the Document History, is approved by the Chief Executive of the Department of Building and Housing. It is effective from 23 June 2007 and supersedes all previous versions of this document.

People using this Compliance Document should check for amendments on a regular basis. The Department of Building and Housing may amend any part of any Compliance Document at any time. Up-to-date versions of Compliance Documents are available from www.dbh.govt.nz

New Zealand Building Code Clause G10 Piped Services

This Clause is extracted from the New Zealand Building Code contained in the First Schedule of the Building Regulations 1992.

68	Building Regulations 1992	1992/150
FIRST SCHEDULE—continued		
Clause G10—PIPED SERVICES		
Provisions	Limits on application	
OBJECTIVE		
<p>G10.1 The objective of this provision is to safeguard people from injury or illness caused by extreme temperatures or <i>hazardous substances</i> associated with <i>building services</i>.</p>		
FUNCTIONAL REQUIREMENT		
<p>G10.2 In <i>buildings</i> provided with potentially <i>hazardous</i> services containing hot, cold, flammable, corrosive or toxic fluids, the installations shall be constructed to provide <i>adequate</i> safety for people.</p>		
PERFORMANCE		
<p>G10.3.1 Piping systems shall be constructed to avoid the likelihood of:</p> <ul style="list-style-type: none"> (a) Significant leakage or damage during normal or reasonably foreseeable abnormal conditions, (b) Detrimental contamination of the contents by other substances, (c) Adverse interaction between services, or between piping and electrical systems, and (d) People having contact with pipes which could cause them harm. 		
<p>G10.3.2 Provision shall be made for the ready removal of moisture or condensate in gas pipes.</p>		
<p>G10.3.3 Pipes shall be protected against corrosion in the environment of their use.</p>		
<p>G10.3.4 Piping systems shall be identified with markings if the contents are not readily apparent from the location or associated equipment.</p>		

1992/150

Building Regulations 1992

69

FIRST SCHEDULE—*continued*

Provisions

Limits on application

G10.3.5 Enclosed spaces shall be constructed to avoid the likelihood of accumulating vented or leaking gas.

G10.3.6 Piped systems shall have isolation devices which permit the installation or individual items of apparatus to be isolated from the supply system, for maintenance, testing, fault detection and repair.

Contents

	Page
References	7
Definitions	11
Verification Method G10/VM1	13
1.0 Soundness Testing	13
Acceptable Solution G10/AS1	15
Piping for Gas used as an Energy Source	
1.0 Pipework Construction	15
1.1 Drainage and cleaning provisions	15
1.2 Pipework installation	15
1.3 Welded joints	17
1.4 Concealed piping	17
1.5 Pipework in ducts	18
2.0 Isolating Valves	19
3.0 Corrosion Control	19
4.0 Vent Lines	19
5.0 Alternative Solution	20
Index	21

ARCHIVED

References

For the purposes of New Zealand Building Code compliance, the acceptable New Zealand and other Standards, and other documents referred to in this Compliance Document (primary reference documents) shall be the editions, along with their specific amendments, listed below. Where the primary reference documents refer to other Standards or other documents (secondary reference documents), which in turn may also refer to other Standards or other documents, and so on (lower order reference documents), then the applicable version of these secondary and lower order reference documents shall be the version in effect at the date this Compliance Document was published.

Amend 4
Jun 2007

Standards New Zealand

		Where quoted
	NZS/BS 21: 1985 Specification for pipe threads for tubes and fittings where pressure-tight joints are made on the threads (metric dimensions)	AS1 Table 1
	NZS/BS 143 and 1256: 1993 Specification for malleable cast iron and cast copper alloy threaded pipe fittings <i>Amend: 1, 2, 3</i>	AS1 Table 1
Amend 2 Dec 1995		
	NZS/BS 1387: 1985 (1990) Specification for screwed and socketed steel tubes and tubulars and for plain end steel tubes suitable for welding or screwing to BS 21 pipe threads	AS1 Table 1
Amend 2 Dec 1995		
	NZS/BS 1560:- Circular flanges for pipes, valves and fittings (Class designated) Part 3:- Steel, cast iron and copper alloy flanges Section 3.1: 1989 Specification for steel flanges Section 3.2: 1989 Specification for cast iron flanges	AS1 Table 1
	NZS/BS 1740:- Specification for wrought steel pipe fittings (screwed BS 21 R-series thread) Part 1: 1971 Metric units (1990) <i>Amend: 1, 2, 3</i>	AS1 Table 1
Amend 1 Sep 1993		
	NZS/BS 2971: 1991 Specification for Class II arc welding of carbon steel pipework for carrying fluids	AS1 1.3.1 a), Table 1
Amend 2 Dec 1995		
	NZS 3501: 1976 Specification for copper tubes for water, gas, and sanitation	AS1 Table 1
	NZS 3502: 1976 Specification for copper and copper alloy tubes for general engineering purposes	AS1 Table 1
	NZS/BS 3601: 1987 (1993) Specification for carbon steel pipes and tubes with specified room temperature properties for pressure purposes	AS1 Table 1
Amend 2 Dec 1995		
	NZS 4203: 1984 Code of practice for general structural design and design loadings for buildings <i>Amend: 1</i>	AS1 1.0.1 a)
Amend 1 Sep 1993		
	NZS 4219: 1983 Specification for seismic resistance of engineering systems in buildings <i>Amend: 1, 2</i>	AS1 1.0.1 a)
Amend 1 Sep 1993		

Amend 4
Jun 2007

NZS/BS 4504:- Circular flanges for pipes, valves and fittings (PN designated)
 Part 3:- Steel, cast iron and copper alloy flanges
 Section 3.2: 1989 Specification for cast iron flanges

NZS 5261: 2003 Gas installation
Amend: 1

NZS 5807:- Code of practice for industrial identification by colour, wording or other coding
 Part 2: 1980 Identification of contents of piping, conduit and ducts

NZS 7646: 1978 Specification for polyethylene pipes and fittings for gas reticulation

Where quoted

AS1 Table 1

VM1 1.0.1,
AS1 5.0.1

Amend 2
Dec 1995
Amends 1
& 3

AS1 1.0.1

Amend 1
Sep 1993

AS1 Table 1

British Standards Institution

BS 10: 1962 Specification for flanges and bolting for pipe, valves and fittings

BS 1640:- Specification for steel butt-welding pipe fittings for the petroleum industry
 Part 3: 1968 Wrought carbon and ferritic alloy steel fittings. Metric units
Amend: 905

Part 4: 1968 Wrought and cast austenitic chromium-nickel steel fittings. Metric units

BS 1723:- Brazing
 Part 1: 1986 Specification for brazing

BS 1845: 1984 Specification for filler metals for brazing

BS 2640: 1982 Specification for Class II oxy-acetylene welding of carbon steel pipework for carrying fluids

BS 3799: 1974 (1994) Specification for steel pipe fittings, screwed and socket-welding for the petroleum industry

AS1 Table 1

AS1 Table 1

Amend 1
Sep 1993

AS1 Table 1

AS1 Table 1

AS1 Table 1

AS1 1.3.1 a),
Table 1

AS1 Table 1

Amend 2
Dec 1995

Standards Association of Australia

AS D26: 1972 Tube fittings with dryseal American standard taper pipe and unified threads for automotive and industrial use

AS 1167:- Welding and brazing – Filler metals
 Part 1: 1993 Filler metal for brazing and braze welding

AS 1432: 1990 Copper tubes for plumbing, gasfitting and drainage applications

AS 3688: 1994 Water supply – Copper and copper alloy compression and capillary fittings and threaded connectors

AS1 Table 1

AS1 Table 1

Amend 2
Dec 1995

AS1 Table 1

AS1 Table 1

Amend 2
Dec 1995

American Society for Testing and Materials

ASTM		
A53-90	Specification for pipe, steel, black and hot-dipped, zinc-coated welded and seamless	
A106-91	Specification for seamless carbon steel pipe for high temperature service	

Where quoted

AS1 Table 1
AS1 Table 1

American National Standards Institute and American Society of Mechanical Engineers

ANSI/ASME		
B16.1-1989	Cast iron pipe flanges and flanged fittings, Class 25, 125, 250 and 800	
B16.3-1985	Malleable-iron threaded fittings, Classes 150 and 300	
B16.5-1988	Pipe flanges and flanged fittings, steel-nickel alloy and other special alloys	
B16.9-1990	Factory-made wrought steel butt-welding fittings	
ANSI		
B16.11-1980	Forged steel fittings, socket-welding and threaded	

AS1 Table 1
AS1 Table 1
AS1 Table 1
AS1 Table 1
AS1 Table 1
AS1 Table 1

American Petroleum Institute

API SPEC 5L-1991	Specification for line pipe	
API STD 1104-1988	Welding of pipelines and related facilities	

AS1 Table 1
AS1 1.3.1 b),
Table 1

ARCHIVED

Definitions

Amend 4
Jun 2007

This is an abbreviated list of definitions for words or terms particularly relevant to this Compliance Document. The definitions for any other italicised words may be found in the New Zealand Building Code Handbook.

Adequate *Adequate* to achieve the objectives of the *building code*.

Amend 4
Jun 2007

Building has the meaning ascribed to it by Sections 8 and 9 of the Building Act 2004.

Hazardous Creating an unreasonable risk to people of bodily injury or deterioration of health.

Intended use in relation to a *building*:

- a) includes any or all of the following:
 - i) Any reasonably foreseeable occasional other use that is not incompatible with the *intended use*; and
 - ii) Normal maintenance; and
 - iii) Activities taken in response to *fire* or any other reasonably foreseeable emergency
- b) but does not include any other maintenance and repairs or rebuilding.

Amend 4
Jun 2007

Regulator A device which automatically regulates the pressure or volume of gas passing through it to a predetermined level.

Safety shut-off system An arrangement of valves and associated control systems which shuts off the supply of gas when required by a device which senses an unsafe condition.

Tailpipe A device placed at the low point of a gas piping system to collect condensate, and from which the condensate may be removed.

Vent line A pipe or tube which conveys gas to a safe place outside the *building* from a gas pressure *regulator* relief valve.

ARCHIVED

Verification Method G10/VM1

1.0 Soundness Testing

Amend 4
Jun 2007

1.0.1 NZS 5261 Appendix D describes acceptable test methods to establish that piping systems will withstand a foreseeable pressure without significant leakage.

ARCHIVED

Acceptable Solution G10/AS1

It is intended that the New Zealand Building Code will in due course provide acceptable solutions for piping a range of fluids and solids. This acceptable solution is restricted to the reticulation of gas (typically natural or *town gas*), used as an energy source.

For water supply piping, an acceptable solution is given in G12/AS1.

Piping for Gas used as an Energy Source

1.0 Pipework Construction

1.0.1 Pipework installed in *buildings* shall:

- a) Be designed in accordance with NZS 4203, and comply with the seismic design and installation requirements of NZS 4219,
- b) Use materials and jointing techniques complying with Table 1,
- c) Have no plain nipples, square back elbows or long screws, and
- d) Have metal (including spirally wound metal) gaskets with a minimum melting point of 500°C.

COMMENT:

Pipework can be identified using the marking conventions given by NZS 5807.

Amend 1
Sep 1993

1.1 Drainage and cleaning provisions

1.1.1 Where condensates can form in a pipeline, they shall be removed by grading the pipe with a fall of 4 mm per metre towards a *tailpipe* (drip), located at the piping low point nearest the outlet side of the meter.

1.1.2 If this is impractical, a single *tailpipe* may be provided at the lowest point in the pipeline, which shall have a fall to that point.

1.1.3 Tailpipes

Tailpipes shall be:

- a) Constructed to provide:
 - i) ready access for cleaning and draining,
 - ii) a trap which on filling will shut off the flow of gas before the condensate can run back to the meter, and
 - iii) protection from frost,

b) Of sufficient capacity for:

- i) the pipes draining into them, and
- ii) the amount of condensate likely to occur, and

c) Installed with a suitable control fitting and plug to allow removal of condensate if the *tailpipe* is below ground.

1.2 Pipework installation

1.2.1 A pipework installation shall have:

- a) Pipes supported in accordance with Table 2,
- b) Pipes separated (by at least 25 mm) from any metallic electrical conduit, or metal armoured or metal sheathed electrical wire,
- c) Pipe risers which are:
 - i) supported by anchors and attachments which are capable of supporting the total weight of the riser and allow for differential expansion,
 - ii) sleeved through floors,
 - iii) not jointed at sleeve locations, and
- d) Pipe bends and offsets which:
 - i) are constructed without buckling, cracks, or physical damage, and
 - ii) give at least the gas-carrying capacity of a standard fitting, and
- e) No piping laid on the ground.

Amend 1
Sep 1993

Table 1: Acceptable Standards for Piping Systems
Paragraph 1.0.1 b)

Material	Acceptable piping	Acceptable fittings	Acceptable jointing	Special conditions
Steel	Steel pipe to NZS/BS 1387, NZS/BS 3601, ASTM A53, ASTM A106 or API 5L.	Screwed pipe fittings, malleable cast iron to NZS/BS 143 and 1256 or ANSI B16.3. Wrought steel to NZS/BS 1740, or ANSI B16.11.	Screwing/socketing to NZS/BS 21.	<ol style="list-style-type: none"> Black pipe: <ol style="list-style-type: none"> is not permitted below ground unless protected. (Galvanising is not sufficient protection.) is not permitted with wet gas. shall be painted or suitably coated when installed above ground. All joints in locations below ground shall be externally protected against corrosion. Welding shall be by welders certified in accordance with API 1104. Flanged joints may only be used when other jointing methods are impracticable.
		Socket-welding pipe fittings, sockets to NZS/BS 3799 or ANSI B16.11. Butt-welding fittings to BS 1640 or ANSI B16.9.	Welding to BS 2640, NZS/BS 2971 or API 1104.	
		Flanges to BS 10, NZS/BS 1560, NZS/BS 4504 or ANSI B16.1 and B16.5.		
Copper	Copper tube to NZS 3501, NZS 3502 or AS 1432.	Copper tube expanded with proper forming tools to provide capillary tolerances.	Brazing in accordance with BS 1723 using copper-phosphorous brazing alloy to AS 1167-1 or BS 1845, with a nominal silver content of not less than 5% and a melting point in excess of 550°C.	<ol style="list-style-type: none"> Not for installation below ground, unless in protective ducting.
		Copper and copper alloy capillary fittings to AS 3688.		
		Copper alloy compression fittings to AS 3688 or AS D26.	Flares formed with proprietary flaring tools.	
Plastic	Polyethylene to NZS 7646.	Fittings to NZS 7646.		Below ground use only.

Amend 1
Sep 1993

Table 2: Pipe Supports Paragraph 1.2.1 a)					
Nominal pipe size (nominal bore of steel or nominal outside diameter of copper)		Horizontal run support spacing		Vertical run support spacing	Minimum rod diameter for single rod hangers
(mm)		(m)		(m)	(mm)
STEEL	COPPER	STEEL	COPPER		
8		2	-		10
10	10	2	1		10
15	15	1.5			10
-	18	-	1.5		10
20	20	2.5	2	At each floor level but in any case not more than 3.0 m	10
25	25	2.5	2		10
32	32	3	2		10
40	40	3	2.5		10
50	50	3	3		10
65	65	3	3		16
80	80	4	3		16
100	100	4	3		16

1.3 Welded joints

1.3.1 Welded joints shall comply with the tests and procedures given in:

- a) BS 2640 or NZS/BS 2971 for pressures up to 420 kPa, or
- b) API 1104 for pressures over 420 kPa.

1.4 Concealed piping

1.4.1 In concrete

Piping installed in concrete shall:

- a) For steel pipes, have a concrete cover of:
 - 75 mm when concrete is cast against the ground,
 - 50 mm when concrete is exposed to the weather, or
 - 35 mm when concrete is indoors, and
- b) Have pipes other than steel, sleeved to allow for expansion, and

- c) Have protection (such as wrapping) from corrosion provided at points of entry and exit from the concrete.

COMMENT:

It is recommended that where practicable, such as in industrial construction, pipes be laid in covered floor channels and be protected against corrosion if necessary.

1.4.2 In enclosed spaces

Piping installed in enclosed spaces shall:

- a) Not be located in lift wells, air ducts, plenum ceilings, air handling plenums, clothes chutes, rubbish chutes, ventilating ducts, fire hydrant cupboards or fire isolated stairways,
- b) In under floor spaces have:
 - i) pipes suspended clear of the ground by a minimum of 100 mm, and
 - ii) enclosed spaces ventilated in accordance with E2/AS1,

- c) In unventilated and/or inaccessible spaces be installed without joints, and
- d) Where joints are unavoidable, have the joint inspected, tested and proved sound before the pipework is concealed.

1.4.3 Underground

Underground pipes shall be:

- a) Sleeved and sealed where they penetrate foundation walls,

COMMENT:

The pipes are sleeved and sealed to prevent gas leakage to the *building*, and damage to the pipe resulting from differential settlement.

- b) Sufficiently buried to protect the piping from physical damage, and have a minimum cover in accordance with Table 3, and
- c) Bedded on firm compacted ground so that:
 - i) pipes are supported along their entire length and are not resting on collars and flanges, and
 - ii) bedding material and backfill within 75 mm of the pipe is free of stones.

COMMENT:

It is recommended that where practicable, such as in industrial construction, pipes be laid in covered floor channels, and be protected against corrosion if necessary.

1.5 Pipework in ducts

1.5.1 False ceiling spaces and void spaces within cavity and partition walls containing pipework, shall be constructed as ventilated ducts.

COMMENT:

Such ventilation should be installed in a way that does not compromise any other New Zealand Building Code requirements such as resistance to the spread of fire, or sound transmission.

Table 3: Piping Cover
 Paragraph 1.4.3 b)

Low and medium pressure	Under lawns, paths and gardens	300 mm
	Under roadways and driveways	450 mm
Intermediate pressure	Under lawns, paths and gardens	450 mm
	Under roadways and driveways	600 mm

1.5.2 Pipes fitted in horizontal ducts which have open grille type covers, shall be treated as above-ground pipes.

1.5.3 Ventilated ducts

Piping shall be permitted in ventilated ducts when:

- a) False ceilings and void spaces within cavity walls are specifically designed and purpose-built as ventilated ducts,
- b) The enclosing walls of the duct are not penetrated by pipes of greater than 150 mm nominal bore,
- c) Wall penetrations by pipes of 150 mm or less nominal bore are:
 - i) the minimum necessary to accommodate the pipe, and
 - ii) the opening is fire-stopped, and
- d) The duct has through-flow ventilation by providing a minimum of one opening at each end of the duct or isolated section of the duct. (For horizontal ducts acceptable openings are located at high and low levels),

- e) A minimum free ventilation opening of 1/150 of the cross-sectional area of the duct or 50,000 mm² whichever is the greater, is provided, and
- f) Pipes within horizontal ducts are located near the bottom of the duct.

1.5.4 Unventilated ducts

The installation of pipes in unventilated ducts should be avoided, but when it is necessary for a pipe to pass through an unventilated duct or void, either:

- a) The pipes shall be continuously sleeved with the sleeve ventilated at one or both ends into a ventilated space, or
- b) The duct void shall be filled with dry, washed sand.

COMMENT:

Dry, washed sand is acceptable because it is inert, non-combustible and non-corrosive.

2.0 Isolating Valves

2.0.1 Gas piping isolating valves shall:

- a) For emergency shut-down of commercial and industrial installations, have their location clearly identified on a drawing permanently and prominently displayed near the primary meter set.
- b) For appliances, be of the 1/4 turn type with the handle marked to indicate the direction of gas flow.
- c) For domestic and light commercial installations, be provided in an accessible location outside the *building*.

2.0.2 To satisfy Paragraph 2.0.1 b), the meter inlet-valve may be used as an isolating valve in accordance with the requirements of the gas supply authority.

3.0 Corrosion Control

3.0.1 Acceptable solutions for the control of pipework corrosion shall provide for:

- a) The installation of a joint which is electrically non-conducting, where a pipe rises above ground,
- b) The separation of electrochemically incompatible materials in underground locations, by joining with insulated components, and
- c) The painting of black steel pipe as soon as practicable after installation unless it is protected with anti-corrosive wrapping.

4.0 Vent Lines

4.0.1 *Vent lines* shall:

- a) Be fitted to all vented *safety shut-off systems*, gas pressure relief devices, and breather vents, installed within a *building*,
- b) Have the vent pipe discharge point located no closer than:
 - i) 1.0 m in any direction from an opening into a *building*, and
 - ii) 2.0 m from any source of ignition, and
- c) Have *vent line* diameters complying with:
 - i) Table 4 for ventilators, or
 - ii) Table 5 for a vented *safety shut-off system*, and
- d) Have no *vent lines* of different types interconnected,
- e) Have no breather vent connected to a safety system shut-off vent,
- f) Have *vent lines* from the same appliance interconnected for:
 - i) safety shut-off *vent lines*, and
 - ii) breather *vent lines*, and

Amend 1
Sep 1993

- g) Have common *vent lines* with a cross-sectional area equal to or greater than the sum of the cross-sectional areas of the two largest *vent lines* being interconnected, and
- h) Have the *vent line* extended to the outside of the *building* and terminating in a breather vent.

4.0.2 Breather vents may be vented within a room or enclosure if the diameter of the vent outlet does not exceed the value 'd' given by the formula:

$$d = [(0.6 \times V)/P^{0.5}]^{0.5}$$

or if the volume of the room exceeds the value of 'V' given by the formula:

$$V = 7.72 d^2 P^{0.5}$$

where:

d = breather vent orifice diameter (mm).

P = inlet pressure to the vented device (kPa).

V = volume of the room or enclosure housing the *regulator* (m³).

Table 4: Diameters of Vent Lines for Ventilators
Paragraph 4.0.1 c) i)

Length of vent line	Minimum diameter
Less than 10 m	No less than the diameter of the vent connection.
10-30 m	One standard pipe diameter above that of the vent connection.
More than 30 m	Sufficient to prevent excessive back pressure taking into account the effect of <i>regulator</i> , inlet pressure, <i>vent line</i> flow resistance and the capacity of the <i>regulator</i> air relief device.

5.0 Another Acceptable Solution

5.0.1 NZS 5261: Part 2 is another Acceptable Solution for Paragraphs 1.0 to 4.0.

Amend 4
Jun 2007

Amend 3
Feb 1998

Table 5: Vent Line Diameters and Lengths for Vented Safety Shut-off Systems
Paragraph 4.0.1 c) ii)

Minimum nominal diameter of vent valve (mm)	Vent pipe length in metres							
	Nominal diameter of vent line (mm)							
	15	20	25	32	40	50	65	80
6	60	160	400					
8	30	80	200					
10	15	40	100					
15	8	20	50					
20		10	25	64				
25			13	32	80			
32				16	40	100		
40					20	50	130	
50						25	65	160

Index G10/VM1 & AS1

All references to Verification Methods and Acceptable Solutions are preceded by **VM** or **AS** respectively.

Gas reticulation		
Amend 4 Jun 2007		another Acceptable Solution AS1 5.0
		cleaning
		see drainage AS1 1.1
		concealed piping AS1 1.4
		in concrete AS1 1.4.1
		in enclosed spaces AS1 1.4.2
		underground AS1 1.4.3, Table 3
		construction AS1 1.0
		corrosion control AS1 3.0
Amend 1 Sep 1993		design AS1 1.0.1 a)
		drainage AS1 1.1
Amend 1 Sep 1993		tailpipes AS1 1.1.3
		installation AS1 1.2
		bends and offsets AS1 1.2.1 d)
		risers AS1 1.2.1 c)
		separation AS1 1.2.1 b)
		supports AS1 1.2.1 a), Table 2
		isolating valves AS1 2.0
Amend 1 Sep 1993		materials AS1 1.0.1 b), Table 1
		pipework in ducts AS1 1.5
		unventilated ducts AS1 1.5.4
		ventilated ducts AS1 1.5.3
		vent lines AS1 4.0, Tables 4 and 5
		welded joints AS1 1.3
		Test methods VM1 1.0

ARCHIVED